

Supplier's declaration of conformity



As required by the following Notices:

- > *Radiocommunications (Compliance Labelling - Devices) Notice 2014* made under section 182 of the *Radiocommunications Act 1992*;
- > *Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2008* made under section 182 of the *Radiocommunications Act 1992*
- > *Radiocommunications (Compliance Labelling – Electromagnetic Radiation) Notice 2014* made under section 182 of the *Radiocommunications Act 1992* and
- > *Telecommunications (Labelling Notice for Customer Equipment and Customer Cabling) Instrument 2015* made under section 407 of the *Telecommunications Act 1997*.

Instructions for completion

- > **Do not return this form to the ACMA.** This completed form must be retained by the supplier as part of the documentation required for the compliance records and must be made available for inspection by the ACMA when requested.

Supplier's details (manufacturer, importer or authorised agent)

Company Name (OR INDIVIDUAL)

SCY International Trading Limited

TRADING AS

ACMA supplier code number

(issued by the ACMA prior to 1 March 2013)

E3403

OR

ACN/ARBN

Street Address (AUSTRALIAN or NEW ZEALAND)

23 Cuba Street

Palmerston North

POSTCODE 4412

Phone: +642102521612

OR

New Zealand IRDN

116073641

Product details and date of manufacture

Product description – brand name, type, current model, lot, batch or serial number (if available), software/firmware version (if applicable)

Company Name: PANDUIT CORP.

Brand Name: PANDUIT CORP.

Model Numbers: PP#&*%%-XXXX

(Note: XXXX: Series number. Shown different outlet combination

%%: Input Current. 16 means 16A, XX means wide range current(24A,32A,40A)

***: Form 0:0U 1:1U 2:2U**

&: Power Input:

1: 200-240Vac, 1 phase

2: 200-240/346-415 Vac (Wye), 3 phase

3: 100-120Vac, 1 phase

4: 200-240Vac (Delta), 3 phase

5: 100-240Vac, 1 phase

6: 120-208Vac (Wye), 3 phase

7: Wide range voltage, 200-240Vac, 1 phase; 200-240Vac (Delta), 3 phase; 200-240/346-415VAC, WYE, 3 phase;
8: Wide range voltage, 200-240Vac (Delta), 3 phase; 200-240/346-415VAC, WYE, 3 phase;
#: Different management feature:
0: Basic PDU
1: Metered iPDU
2: Metered, Outlet switched iPDU
5: Outlet Metered iPDU
6: Outlet Metered, Outlet switched iPDU)

Description: Power Distribution Unit

Compliance – applicable standards and other supporting documents

Evidence of compliance with applicable standards may be demonstrated by test reports, endorsed/accredited test reports, certification/competent body statements.

Having had regard to these documents, I am satisfied the above mentioned product complies with the requirements of the relevant ACMA Standards made under the *Radiocommunications Act 1992* and the *Telecommunications Act 1997*.

List the details of the documents the above statement was made, including the standard title, number and, if applicable, number of the test report/endorsed test report or certification/competent body statement

Standard	Report Number
EN 55032:2015 EN 61000-3-12:2011, EN 61000-3-11:2000, EN 55035:2017	EN200615028E

Declaration

I hereby declare that:

1. I am authorised to make this declaration on behalf of the Company mentioned above,
2. the contents of this form are true and correct, and
3. the product mentioned above complies with the applicable above mentioned standards and all products supplied under this declaration will be identical to the product identified above.

Note: Under section 137.1 of the *Criminal Code Act 1995*, it is an offence to knowingly provide false or misleading information to a Commonwealth entity.

Penalty: 12 months imprisonment



Ke CHEN

Director

22 Jul 2020

SCY International Trading Limited

23 Cuba Street Palmerston North 4412, New Zealand

Tel: +642102521612 Email: chenkenba@hotmail.com